

ATTACHMENT 3, Exhibit A: WATER REQUIREMENTS FOR NON-R&R OPTIONS

		340,000 CPM Floor				320,000 CPM Floor				286,000 CPM Floor			
		Deficit	Storage Needs without pulses	Deficit with Pulses	Storage Needs with Pulses	Deficit	Storage Needs without Pulses	Deficit with Pulses	Storage Needs With Pulses	Deficit	Storage Needs	Deficit with Pulses	Storage Needs
Comal Springs	30 cfs	65,400	111,180	89,658	152,420	39,400	66,980	56,442	95,952	16,100	27,370	24,989	42,481
	40 cfs	93,300	158,610	113,225	192,483	59,100	100,470	73,363	124,717	25,500	43,350	34,962	59,435
	50 cfs	124,900	212,330	139,113	236,491	82,500	140,250	98,198	166,936	38,600	65,620	47,316	80,437
San Marcos Springs	52 cfs	16,700	20,040	25,840	31,008	7,200	8,640	16,875	20,250	1,800	2,160	8,535	10,242
	65 cfs	32,800	39,360	37,804	45,365	19,600	23,520	24,908	29,889	8,800	10,560	11,747	14,096
	75 cfs	54,600	65,520	56,960	68,352	37,200	44,640	46,800	56,160	23,300	27,960	25,991	31,189